**NOTED & REGISTERED** 

Page No. 0.2 Sr. No.50/21
Dated. 27.14/2021



NOTARY

Amravati Municipal Corporation Amravati Fire and Emergency Services Department

No Objection Certificate of Fire Department No.436

Adv.

OMESH P. KHOPE

To. Warud, To,

Dist. Amravati (MAH.)

Rego. No. 16371

Exp. Ot. 26-01-2025

Podar International School S.no. 84/2, Near Pote Farm Kathora Road, Amravati Officer of Firefighting Dept.
Outward no. A.M.C./FFD/147/20
Date: 01/01/2021

Reference: 1. Your received application dt.\_\_\_\_ for grant of No-Objection

2. Fire Safety Audit Report dt.\_\_\_ of Indane Fire Protection, an authorised agent.

Notary Govt. of India Ward No. 2, Sai Baba Colony, Ring Road, Warud, Tg. Warud, Dist. Amravati,

**No-Objection Certificate** 

Amravati, Mcharashtra-444806 certified that, Podar International School has applied for the grant of no-objection certificate for the educational purpose to and from the firefighting department, Municipal Corporation, Amravati, as per the application in reference no.1 and on the basis of Fire safety audit done by Government authrorised agent mentioned in reference no.2. As well as on 18/12/2020 Fire Department officer/authorised officer has done the technical inspection. Accordingly, No-Objection certificate is granted to you subject to following terms and conditions.

- 1. Fire Prevention measures plans and mechanisms as per the provisions of Maharashtra Fire Prevention and Life Safety Measures Act,2006 should be complied by you AND NBC-2016 rules should be abided by you AS WELL AS you will be bounded by rules and changes in them made, time to time, by the Government of Maharashtra and Amravati Municipal Corporation.
- 2. Fire Safety and protection System should be done and implemented in accordance with the Fire Safety Audit. No-Smoking (Smoking Prohibited) sign boards should be affixed at every place where it is necessary AND boards of important telephone numbers, for example phone numbers of police control room, fire department, ambulance, etc., should be affixed at places where they can be easily visible.

## NOTARY

- 3. Fire Safety training should be imparted twice a year i.e. in January and in July from licensed agents registered with the Hon'ble Director, Fire Fighting Services, Mumbai.
- 4. Your whole staff should be well informed about the Fire Extinguishing devices from time to time, as well as, practice drills should be exercised from time to time.
- 5. Care should be taken to see that the Fire Prevention measures and systems always remain operational (in working condition), all electrical equipment and devices should be checked and inspected from a trustworthy agent.
- 6. The fire fighting team can at any time inspect the fire prevention equipments under the fire prevention measure plan. The permits of other departments should also be obtained along with the noobjection certificate of Fire fighting department.

The validity of no-objection certificate shall be of one year.

If any fire accident occurs due to mismanagement of the abovementioned directions, the applicant management shall be wholly responsible for such accident.

- 9. It shall be binding to obtain renewed no-objection certificate every year by paying the requisite renewal charges.
- 10. Violation of the provisions of the said acts or of the rules made therefor, or failure in compliance, as required, of any order, direction or notice given as per the provisions of the said act or rules will result in proceedings in the concerned matter as per section 7,8,36.
- 11. Non-fulfilment of the above terms shall lead to cancellation of your no-objection certificate, for which you shall be wholly responsible.

The above certificate shall be valid till 31/12/2021.

Note: 1. It shall be mandatory to renew the No-objection certificate of Fire Department every year.

2. As per the Government Rules, it shall be mandatory to present Form-B every six months.

---Sd---

Commissioner/Dy. Commissioner/Fire Superintendent Amravati Municipal Corporation, Amravati.



SHP. KHOPE a. Warud.

.mravati (MAH.) an. No. 16371

Dt. 25-01-2025





