



MAHARASHTRA STATE PUBLIC HEALTH SERVICES

DISTRICT PUBLIC HEALTH LABORATORY JALGAON

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

dphljal@gmail.com
dprljal@gmail.com

Phone: (0257)2229221

Name & Address of Sender.	Admin. officer, podar International School, Bhusawal.			
Sender's Letter No. & Date	24-12-2024			
Laboratory Reference No.	8556 to 8558			
Date of Collection	-			
Date of Arrival at Laboratory	24-12-2024			
Date of Commencing Examination :-	— 11 —			
Sr. No.	Particular of Water Samples	Result of Analysis Most Probable Number Per 100 ml.		Remark
		Coliforms	Thermotolerant Coliforms	
1	RO Water sample (New Building Girls)	00	-	fit for drinking
2	RO Water sample (old Building podar prep)	00	-	fit for drinking
3	RO Water sample (old Building podar prs Boys)	00	-	fit for drinking
		 (COLONEL AMOL K KONDE) (कर्नल अमोल के कोण्डे) General Manager-Nashik-2 महाप्रबंधक, नाशिक क्षेत्र-२		
	 Principal Podar International School, Bhusawal			
Remark: Unfit water samples can be used, only after proper treatment, chlorination and retesting bacteriologically to ascertain its / their fitness for drinking purposes.				
Note :- Above water sample was not collected by this laboratory.				
Govt. Receipt No. 3219777	Dt 24/12/2024	Rs. 1020/-		

Report outward No. :- 4081

Date :- 31.12.2024


 Junior Scientific Officer
 District Public Health Laboratory
 Jalgaon - 425 001

