

Annexure D

BUILDING SAFETY CERTIFICATE

No.

Dated: 31/12/2024

It is certified that the existing building **Podar International School** at **Plot No. 75 / Survey No. 307/1+308/1+309/501/1+501/2/1 / Khasra No. (s) Chavadigram, Opp. Kadi Kadi Karkhana, Taluka Chalisgaon / Disctrict Jalgaon** is having block(s)/Floors as per details below:-

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	0 Basement, 1 Ground Floor 2 Upper Floors	NA	NA	NA	NA	NA


The building is occupied by **Podar International School, Plot No. 75 / Survey No. 307/1+308/1+309/501/1+501/2/1 / Khasra No. (s) Chhayadigram, Opp. Kadi Karkhana, Tal.Chalisgaon** have complied with the Building safety requirements in accordance with National Building code Rules and verified by the officers concerned of **P.W.Sub-Division**, on 23/12/2024 in the presence of **Anil N. Baisane**, Sub-Divisional Engineer, P.W.Sub Division, Chalisgaon 424101 and the building/ premises is fit for occupancy for running the school from **31/12/2024** for a period of 1 year in accordance with rule and subject to compliance of the specific conditions as appended.

1. Drive way of minimum 6.00 m shall be provided without any Obstruction around main building for fire extinguisher vehicle.
2. Water proofing for First Floor Toilet Blocks should be done properly.

Issued on **31/12/2024** at P.W.Sub Division, Chalisgaon by Sub-Divisional Engineer.

*Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

जा.क्र.सा.बा.उद्या।। 266 सन 205
उपविभागीय अभियंता यांचे कार्यालय
सार्वजनिक बांधकाम उपविभाग, राजीसांगव
दिनांक: 31 / 12 205


Anil N. Baisane
Sub-Divisional Engineer
P.W. Sub-Division, Chalisgaon.


PRINCIPAL
Podar International School
Chalisgaon