



# JUNAGADH MUNICIPAL CORPORATION FIRE & EMERGENCY SERVICES

"SWAMI VIVEKANAND BHAVAN", AZAD CHOWK, JUNAGADH-362001

PH.No. 0285-2622089, FAX No. 0285-2651510

E-mai :municipalcorporationjund@yahoo.co.in



Ju.M.C./Fire/Noc/Outward/No. 29

Date:- 4/09/2022

## NO OBJECTION CERTIFICATE

This is to certify that the management of **Podar Internation School** Located at **Near Mahasagar Petrol Pump Junagadh Rajkot Highway, Junagadh** has provided adequate Fire Protection measures.

The Fire Department has NO OBJECTION to the said premises as required level of Fire Protection is provided as under.

Sr. No.	Item Name	Number Of Item
1	5 kg capacity ABC type Fire Extinguishers	15
2	4 kg capacity ABC type Fire Extinguishers	8
3	2 kg & 4.5 kg Capacity CO2 type Fire Extinguishers	8
4	Hose Reel	Each Floor
5	Hose Box	Each Floor
6	Fire Pump 7.5 HP	01
7	Fire Alarm Penal	01
8	Fire Inlet (2 Way)	01
9	Pump On Of Switch	Each Floor

All Extinguishers / items shall be maintained in working order throughout the validity period of this certificate. (\* if you can't complete all works within 30 days which is suggested by fire officer, than this NOC is automatically be invalid.)

This Certificate is valid till **Three Year**



  
Chief Fire Officer  
Municipal Corporation,  
Junagadh