## PROFORM FOR SAFE DRINKING WATER AND SANITRAY CONDITION CERTIFICATE

NO: MANSN 0026/23-24

Dated: 22-3-2024

It is certified that an inspection team headed by Shivaraju, Executive Engineer, Rural Drinking Water and Rural Sanitation Department, Division, Mandya inspected the Podar International School No.74/13, H Kodihalli Village, Kasaba Hobli, Mandya Taluk, Mandya District—571402 on 20/03/2024 and on the basis of Water Test bearing no PVT 24MAR006 dated 22/03/2024 of District Water Quality Testing Laboratory, RDW and SD, Mandya certified that the Podar International School, Mandya has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U T Govt

This certificate is valid till 24.03.2026

Signature with Seal... Office of the Executive Engineer R.D.W. & S. Division, Mandya-571 401.

Name: 5- SHIYARAJU

Designation: EXCUTTURE ENGINEER.

Name and Address of the office

R.D. KIKS D

MANDYA

To

Podar International School

No.74/13, H Kodihalli Village, Kasaba Hobli,

Mandya Taluk , Mandya District - 571402

PRINCIPAL Podar International Scho

No.74/13, H. Kodihalli Villege H. Malliyere (P), Mandya-571402

Podar International School Survey No.74/13, H. Kodihalli Village, Kasaba Hobb Mandya-571402



District Water Quality Testing Laboratory Mandya O/o Executive Engineer, Rural Drinking Water & Sanitation Division,

## Opp.Rural Police Station, Bannuru road, Mandya 571401

e-mail: rdwsd.wqmsp.mandya@gmail.com

		TEST	REPORT	incom	
	R INTERNATIONAL SCHOOL		Report date:22.03.2024		
MANDYA NO 74/13			Reference:Sample receipt from		
H.KODIHALLI VILLAGE			Sample code:PVT24MAR0006		
H.MALLIGERE (POST)			Date of Sample collection: 20.03.2024		
KASABA (HOBLI) MANDYA - 571402			Date of Sample receipt: 20.03.2024		
			Analysis start date:21.03.2024		
. /		.*	Analysis completion date:21.03.2024		
Sample Particulars:RO(DRINKING WATER)			Sample collection protocol: APHA(23rd Edition)1060		
Sł.No	Test Parameter	Results	Acceptable Limit IS 10500 : 2012	Permissible Limit IS 10500	
1	Colour, Hazen Units	<1	5	15	IS 2025 (Dart 4) 2024
2	Odour	Agreeable	Agreeable	not Agreeable	IS 3025 (Part-4) :2021
3	pH Value @Temp	7.73@ 25°C	6.5 - 8.5	No relaxation	(10100)12020
4	Turbidity, NTU	<0.5	1	5	1. 011 221. 2022
5	Specific Conductance, µS/cm @	59.08μS/cm @		3	IS 3025 (Part-10) : 2023
	Temp	25°C	-	-	IS 3025 (Part-14) :2013
6	Total Dissolved Solids @180°C, mg/l	32	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO <sub>3,</sub> mg/l	28.1	200	600	IS 3025 (Part-23) : 1986
8	Total Hardness as CaCO <sub>3</sub> , mg/l	22	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	5.3	75	200	
10	Magnesium as Mg, mg/l	2.1	30	100	IS 3025 (Part-40) : 1991
11	Chloride as Cl, mg/l	5.2	250	1000	IS 3025 (Part-46) : 2023
12	Fluoride as F, mg/l	0.14	1	1.5	IS 3025 (Part-32) : 1988
13	Sulphate as SO <sub>4</sub> , mg/l	0.1	200	400	APHA 23 <sup>rd</sup> Edition4500-F:D IS 3025 (Part-24/Sec 1): 2022
14	Nitrate as NO <sub>3</sub> , mg/l	<01	45	No relaxation	APHA 23 <sup>rd</sup> Edition4500-NO3
15	Iron as Fe, mg/I	< 0.1	1	No relaxation	IS 3025 (Part-53) : 2003
mark:	All the above Tested parameter Co	nforms Accental	ale Limit As no		13 3023 (3 811-33) . 2003
	Sidehiya	morns Acceptat	ne Limit, As pe	er is 10500:2012	Specification.
	Reviewed by:				
Quality Manager					Authorized Signatory:
	(ASHWINI S)			}	Technical Manager
WSD/W	QMSP/TeR/01				(JAYASHEELA R S) District Water Quality

## Note:

1) The above results relate only to the sample tested.

2) The report shall not be reproduced except in full without the prior approval of the Quality Margue & SD, Mandya.

Traceability: Traceability of measurements is established using CRMs traceable to National/International standards 3)

Samples will be discarded after 15 days from the date of report generation.

Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

.....End Of Report.....

Manager
Podar International School Survey No.74/13, H. Kodihalli Village, Kasaba Hobbi

H. Malligere (P), Manaya-57

**Testing Laboratory**