



मिरा भाईंदर महानगरपालिका

MIRA-BHAINDAR MUNICIPAL CORPORATION



कार्यालय : स्व. इंदिरा गांधी भवन, छत्रपती शिवाजी महाराज मार्ग, भाईंदर (प.), ता. जि. ठाणे - ४०१ १०१.

दूरध्वनी: 022-28192828 / 28193028 / 28181183 / 28181353 / 28145985

ईमेल: mbmcho@gmail.com वेबसाईट: www.mbmcho.gov.in

स्वातंत्र्याचा अमृत महोत्सव

मुख्य कार्यालय

जा. क्र. मिभा / मनपा / २२४९ / २०२३-२४

दिनांक: ११/०३/२०२४

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

It is certified that an inspection team headed by Shri. Ganesh Nikam, MPW from Public Health Department, Mira Bhayander Municipal Corporation inspected the Podar International School – Mira Road at (address) Survey No 21-2B & 24-3 Ghodbunder, Mira Road, Taluka & District Thane (Name & Address of the School) on Dt. 01/03/2024 and on basis of Water Testing Report (Attached) bearing No Ref./T.M.C./P.C.C./V.Lab - 2844 -A, Sample No – P1280 dated 05th Jan 2024 certified that the Podar International School – Mira Road (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Mira Bhayander Municipal Corporation

This certificate is valid till: 01/03/2025



Signature with Seal: B.T. Dudhbhate

Name:

Dr. B. T. Dudhbhate

Designation:

Medical Officer of Health

To

Podar International School – Mira Road,

Survey No 21-2B & 24-3 Ghodbunder, Mira Road, Taluka & District Thane.

PODAR INTERNATIONAL SCHOOL
MIRA ROAD
Manager

PODAR INTERNATIONAL SCHOOL
MIRA ROAD
Principal

“आपली जबाबदारी व अधिकार, मजबूत लोकशाहीचा आधार”

“जागरूक मतदार लोकशाहीचा आधार”



ठाणे महानगरपालिका THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 2844 -A
Sample No. : P1280

Date : 5 January 2024

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S Podar International School

Address : Survey no-21-2B, 24-3 at Village Ghodbunder, Mira Road (East)- 401107

E_mail ID : admin.miraroad@podar.org

Date of receiving Sample : 04 January 2024

Sample Collected by : Party

Type of Water Sample : Storage Drinking water

Parameters	Results	Limits as per IS 10500
pH	7.30	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	28.0	250 mg/L
Total Hardness	70.0	300 mg/L
Total Coilform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

5-Jan-24

Prabhatkar Sonawale

Thane Municipal Corporation, Thane

Authorised by

5-Jan-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking water Water sample received to our Vakratunda Laboratory on 4/1/2024. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000267/23-24 dated 04.01.2024

This Report has been Signature Digitally.

PODAR INTERNATIONAL SCHOOL
MIRA ROAD

Principal

PODAR INTERNATIONAL SCHOOL
MIRA ROAD

Manager