



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 2844 -A
Sample No. : P1280

Date : 5 January 2024

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S Podar International School

Address : Survey no-21-2B, 24-3 at Village Ghodbunder, Mira Road (East)- 401107

E_mail ID : admin.miraroad@podar.org

Date of receiving Sample : 04 January 2024

Sample Collected by : Party

Type of Water Sample : Storage Drinking water

Parameters	Results	Limits as per IS 10500
pH	7.30	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	28.0	250 mg/L
Total Hardness	70.0	300 mg/L
Total Coilform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

5-Jan-24

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

5-Jan-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking water Water sample received to our Vakratunda Laboratory on 4/1/2024. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000267/23-24 dated 04.01.2024

This Report has been Signature Digitally.