



District Laboratory Nadiad
O/o The Executive Engineer
Gujarat Water Supply and Sewerage Board,
D-Block, 1st Floor, Room No.308,
Sardar Patel Bhavan,
Mill Road, Nadiad-387001,
District- Kheda(Gujarat)
Phone No.- 0268-2565296



E Mail:
dinadiad@gmail.com

જિલ્લા પાલિકાના નડિયાદ
કાર્યપાલક ઈજનેરશ્રીની કચેરી,
ગુજરાત પાણી પુરવઠા અને ગટર વ્યવસ્થા બોર્ડ
રૂમ નં - ૩૦૮, બ્લોક - ડી, સીપી ભાવ,
સરદાર પટેલ ભવન,
મીલ રોડ, નડિયાદ - ૩૮૭૦૦૧
જિલ્લો - ખેડા(ગુજરાત)
ફોન નં - ૦૨૬૮-૨૫૬૫૨૯૬



TC- 11926

Test Report

Name & Address of Customer *:-

Podar International School

Juna Dumral Road,

Nadiad

Tal.Nadiad

Dist.Kheda

Customer Reference No. *: Nil/Dt.01/01/2026

Sample Submitted by: Customer

Date of Sample Collection: 01.01.2026

Date of Sample Receipt: 01.01.2026

Analysis Starting Date: 02.01.2026

Analysis Completion Date: 02.01.2026

ULR No: TC11926260000001F

Test Report No:	2082/2025-26	Discipline :	Chemical	Group:	Water
Sample ID:	KCW-2082/01-2026	Date of Issue:			03.01.2026
Customer ID *:	1	Mode of Sample:			Satisfactory
Main Source *:	Ground Water	Source *:			Tube Well - 1
Location *:	Tap Water From R.O Filter In The School				
Village *:	Nadiad	Habitation *:			Nadiad
Taluka *:	Nadiad	District *:			Kheda
Latitude *:	---	Longitude *:			---
Kindly find herewith the Analytical Results.		Sample Type: Drinking Water			
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value	
1	Colour	Hazen	APHA (24 th Edition), Method: 2120 B	1	
2	Odour	-	IS 3025 (Part 5) Second Revision	Agreeable	
3	Taste	-	IS.3025 (Part 8)	Agreeable	
4	Turbidity	NTU	APHA (24 th Edition), Method: 2130 B	0.52	
5	pH at 25 °C	-	APHA (24 th Edition), Method: 4500 ^H B	7.65	
6	Conductivity at 25 °C	µS/cm	APHA (24 th Edition), Method: 2510 B	91	
7	Total Dissolved Solids	mg/L	APHA (24 th Edition), Method: 2540 C	56	
8	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2340 C	32	
9	Calcium (as Ca ⁺²)	mg/L	APHA (24 th Edition), Method: 3500 Ca ⁺² B	5	
10	Magnesium (as Mg ⁺²)	mg/L	APHA (24 th Edition), Method: 3500-Mg ⁺² B	5	
11	Chloride (as Cl ⁻)	mg/L	APHA (24 th Edition), Method: 4500-Cl ⁻ B	12	
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24 th Edition), Method: 4500-SO ₄ ⁻² E	1.66	
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Edition), Method: 4500-NO ₃ ⁻ B	BDL	
14	Fluoride (as F ⁻)	mg/L	APHA (24 th Edition), Method: 4500-F ⁻ C	BDL	
15	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2320 B	28	

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Abbreviations : BDL= Below Detection Limit, UDL= Upper Detection Limit
6. Disclaimer : Information marked by "*" is provided by the customer.

Checked & Issued By:

(Signature)
Nilofar A.Luhar
Authorised Signatory

O.W.No. DL Nadiad / 35 /of 2026, Dt. 02/02/2026

End of the Test Report

(Signature)
PRINCIPAL

PODAR INTERNATIONAL SCHOOL
NADIAD

(Signature)
General Manager

PODAR INTERNATIONAL SCHOOL



District Laboratory Nadiad
O/o The Executive Engineer
Gujarat Water Supply and Sewerage Board,
D-Block, 3rd Floor, Room No.308,
Sardar Patel Bhavan,
Mill Road, Nadiad-387001,
District- Kheda(Gujarat)
Phone No.- 0268-2565296



E Mail:
dinadiad@gmail.com

જિલ્લા પાણીપુરવઠા નદિયાદ
અધિકારીક ઈજનેરશ્રીની કચેરી,
ગુજરાત પાણી પુરવઠા અને ગટર વ્યવસ્થા બોર્ડ
રૂમ નં - ૩૦૮,૫૦૮ - ડી. ટી.જી. બાવ,
સરદાર પટેલ ભવન,
મીલ રોડ, નદિયાદ - ૩૮૭૦૦૧
જિલ્લો - ખેડા(ગુજરાત)
ફોન નં - ૦૨૬૮-૨૫૬૫૨૯૬



TC- 11926

Test Report

Name & Address of Customer *:-

Podar International School

Juna Dumral Road,

Nadiad

Tal Nadiad

Dist.Kheda

Customer Reference No. *: Nil/Dt.01/01/2026

Sample Submitted by: Customer

Date of Sample Collection: 01.01.2026

Date of Sample Receipt: 01.01.2026

Analysis Starting Date: 02.01.2026

Analysis Completion Date: 02.01.2026

ULR No: TC11926260000002F

Test Report No:	2083/2025-26	Discipline :	Chemical	Group:	Water
Sample ID:	KCW-2083/01-2026	Date of Issue:			03.01.2026
Customer ID *:	2	Mode of Sample:			Satisfactory
Main Source *:	Ground Water	Source *:			Tube Well - 2
Location *:	Tap Water From R.O.Filter In The School				
Village *:	Nadiad	Habitation *:			Nadiad
Taluka *:	Nadiad	District *:			Kheda
Latitude *:	---	Longitude *:			---
Kindly find herewith the Analytical Results.		Sample Type: Drinking Water			
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value	
1	Colour	Hazen	APHA (24 th Edition), Method: 2120 B	1	
2	Odour	-	IS 3025 (Part 5) Second Revision	Agreeable	
3	Taste	-	IS 3025 (Part 8)	Agreeable	
4	Turbidity	NTU	APHA (24 th Edition), Method: 2130 B	0.64	
5	pH at 25 °C	-	APHA (24 th Edition), Method: 4500 H ⁺ B	7.72	
6	Conductivity at 25 °C	µS/cm	APHA (24 th Edition), Method: 2510 B	175	
7	Total Dissolved Solids	mg/L	APHA (24 th Edition), Method: 2540 C	110	
8	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2340 C	20	
9	Calcium (as Ca ²⁺)	mg/L	APHA (24 th Edition), Method: 3500 Ca ²⁺ B	BDL	
10	Magnesium (as Mg ²⁺)	mg/L	APHA (24 th Edition), Method: 3500-Mg ²⁺ B	BDL	
11	Chloride (as Cl ⁻)	mg/L	APHA (24 th Edition), Method: 4500-Cl ⁻ B	12	
12	Sulphate (as SO ₄ ²⁻)	mg/L	APHA (24 th Edition), Method: 4500-SO ₄ ²⁻ E	3.89	
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Edition), Method: 4500-NO ₃ ⁻ B	BDL	
14	Fluoride (as F ⁻)	mg/L	APHA (24 th Edition), Method: 4500-F ⁻ C	0.56	
15	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2320 B	80	

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500.2012 (2nd Revision) limits.
5. Abbreviations : BDL= Below Detection Limit, UDL= Upper Detection Limit
6. Disclaimer : Information marked by " * " is provided by the customer.

Checked & Issued By:

Nilofar A. Luhar
Authorised Signatory

O.W.No. DL Nadiad / 30 / of 2026, Dt. 02 / 01 / 2026

End of the Test Report

PRINCIPAL
PODAR INTERNATIONAL SCHOOL
NADIAD

General Manager
PODAR INTERNATIONAL SCHOOL



District Laboratory Nadiad
O/o The Executive Engineer
Gujarat Water Supply and Sewerage Board,
D-Block, 3rd Floor, Room No.108,
Sardar Patel Bhavan,
Mill Road, Nadiad-387001,
District- Kheda(Gujarat)
Phone No.- 0268-2565296



E Mail:
dinadiad@gmail.com

જાલ્લા પંચાયતવાર નડિયાદ
અધિકારીક ઇન્જિનેરશ્રીની કચેરી,
ગુજરાત પાણી પુરવઠા અને ગટર વ્યવસ્થા બોર્ડ
રૂમ નં - ૩૦૮, બ્લોક - ડી, સીકો ધાલ,
સરદાર પટેલ ભવન,
મીલ રોડ, નડિયાદ - ૩૮૭૦૦૧
જાલ્લો - ખેડા(ગુજરાત)
ફોન નં - ૦૨૬૮-૨૫૬૫૨૬૬



TC- 11926

Test Report

Name & Address of Customer *:-

Podar International School

Juna Dumral Road,

Nadiad

Tal.Nadiad

Dist.Kheda

Customer Reference No. *: Nil/DL/01/01/2026

Sample Submitted by: Customer

Date of Sample Collection: 01.01.2026

Date of Sample Receipt: 01.01.2026

Analysis Starting Date: 02.01.2026

Analysis Completion Date: 02.01.2026

ULR No: TC119262600000003F

Test Report No:	2084/2025-26	Discipline :	Chemical	Group:	Water
Sample ID:	KCW-2084/01-2026	Date of Issue:			03.01.2026
Customer ID *:	3	Mode of Sample:			Satisfactory
Main Source *:	Ground Water	Source *:			Tube Well - 3
Location *:	Tap Water From R.O.Filter In The School				
Village *:	Nadiad	Habitation *:			Nadiad
Taluka *:	Nadiad	District *:			Kheda
Latitude *:	---	Longitude *:			---
Kindly find herewith the Analytical Results.		Sample Type: Drinking Water			
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value	
1	Colour	Hazen	APHA (24 th Edition), Method: 2120 B	1	
2	Odour	-	IS 3025 (Part 5) Second Revision	Agreeable	
3	Taste	-	IS 3025 (Part 8)	Agreeable	
4	Turbidity	NTU	APHA (24 th Edition), Method: 2130 B	0.74	
5	pH at 25 °C	-	APHA (24 th Edition), Method: 4500 H ⁺ B	7.59	
6	Conductivity at 25 °C	µS/cm	APHA (24 th Edition), Method: 2510 B	138	
7	Total Dissolved Solids	mg/L	APHA (24 th Edition), Method: 2540 C	86	
8	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2340 C	28	
9	Calcium (as Ca ⁺²)	mg/L	APHA (24 th Edition), Method: 3500 Ca ⁺² B	8	
10	Magnesium (as Mg ⁺²)	mg/L	APHA (24 th Edition), Method: 3500-Mg ⁺² B	BDL	
11	Chloride (as Cl ⁻)	mg/L	APHA (24 th Edition), Method: 4500-Cl ⁻ B	8	
12	Sulphate (as SO ₄ ⁻²)	mg/L	APHA (24 th Edition), Method: 4500-SO ₄ ⁻² E	4.67	
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Edition), Method: 4500-NO ₃ ⁻ B	BDL	
14	Fluoride (as F ⁻)	mg/L	APHA (24 th Edition), Method: 4500-F ⁻ C	0.38	
15	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2320 B	64	

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Abbreviations : BDL= Below Detection Limit, UDL= Upper Detection Limit
6. Disclaimer : Information marked by " * " is provided by the customer.

Checked & Issued By:

Nilofar A. Luhar

Authorised Signatory

O.W.No. DL Nadiad / 30 / of 2026, Dt. 02 / 01 / 2026

End of the Test Report

PRINCIPAL

PODAR INTERNATIONAL SCHOOL
NADIAD

General Manager

PODAR INTERNATIONAL SCHOOL



District Laboratory Nadiad
O/o The Executive Engineer
Gujarat Water Supply and Sewerage Board,
D-Block, 3rd Floor, Room No.308,
Sardar Patel Bhavan,
Mill Road, Nadiad-387001,
District- Kheda(Gujarat)
Phone No.- 0268-2565296



E Mail:
dlfnadiad@gmail.com

જિલ્લા પંચાયતના નડિયાદ
કાર્યાલય ઉજનેરશ્રીની કચેરી,
ગુજરાત પાણી પુરવઠા અને ગટર વ્યવસ્થા બોર્ડ
૩મ નં - ૩૦૮,૩૦૯ - ડી, ૩ીજો માલ,
સરદાર પટેલ ભવન,
મીલ રોડ, નડિયાદ - ૩૮૭૦૦૧
જિલ્લો - ખેડ(ગુજરાત)
ફોન નં - ૦૨૬૮-૨૫૬૫૨૯૬



TC- 11926

Test Report

Name & Address of Customer *:-

Podar International School
Juna Dumral Road,
Nadiad
Tal.Nadiad
Dist.Kheda

Customer Reference No. *: Nil/Dt.01/01/2026

Sample Submitted by: Customer
Date of Sample Collection: 01.01.2026
Date of Sample Receipt: 01.01.2026
Analysis Starting Date: 02.01.2026
Analysis Completion Date: 02.01.2026
ULR No: TC11926260000004F

Test Report No:	2085/2025-26	Discipline :	Chemical	Group:	Water
Sample ID:	KCW-2085/01-2026	Date of Issue:	03.01.2026		
Customer ID *:	4	Mode of Sample:	Satisfactory		
Main Source *:	Ground Water	Source *:	Tube Well - 4		
Location *:	Tap Water From R.O Filter In The School				
Village *:	Nadiad	Habitation *:	Nadiad		
Taluka *:	Nadiad	District *:	Kheda		
Latitude *:	---	Longitude *:	---		
Kindly find herewith the Analytical Results.			Sample Type: Drinking Water		
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value	
1	Colour	Hazen	APHA (24 th Edition), Method: 2120 B	1	
2	Odour	-	IS.3025 (Part 5) Second Revision	Agreeable	
3	Taste	-	IS.3025 (Part 8)	Agreeable	
4	Turbidity	NTU	APHA (24 th Edition), Method: 2130 B	0.55	
5	pH at 25 °C	-	APHA (24 th Edition), Method: 4500 H ⁺ B	7.62	
6	Conductivity at 25 °C	µS/cm	APHA (24 th Edition), Method: 2510 B	157	
7	Total Dissolved Solids	mg/L	APHA (24 th Edition), Method: 2540 C	98	
8	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2340 C	28	
9	Calcium (as Ca ²⁺)	mg/L	APHA (24 th Edition), Method: 3500 Ca ²⁺ B	6	
10	Magnesium (as Mg ²⁺)	mg/L	APHA (24 th Edition), Method: 3500-Mg ²⁺ B	BDL	
11	Chloride (as Cl ⁻)	mg/L	APHA (24 th Edition), Method: 4500-Cl ⁻ B	12	
12	Sulphate (as SO ₄ ²⁻)	mg/L	APHA (24 th Edition), Method: 4500-SO ₄ ²⁻ E	10.87	
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Edition), Method: 4500-NO ₃ ⁻ B	BDL	
14	Fluoride (as F ⁻)	mg/L	APHA (24 th Edition), Method: 4500-F ⁻ C	0.38	
15	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2320 B	64	

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Abbreviations : BDL= Below Detection Limit, UDL= Upper Detection Limit
6. Disclaimer : Information marked by " * " is provided by the customer.

Checked & Issued By:

Nilofar A. Luhar
Authorised Signatory

O.W.No. DL Nadiad / 30 / of 2026, Dt. 02 / 02 / 2026

End of the Test Report

PRINCIPAL
PODAR INTERNATIONAL SCHOOL
NADIAD

General Manager
PODAR INTERNATIONAL SCHOOL



District Laboratory Nadiad
O/o The Executive Engineer
Gujarat Water Supply and Sewerage Board,
D-Block, 3rd Floor, Room No.308,
Sardar Patel Bhavan,
Mill Road, Nadiad-387001,
District- Kheda(Gujarat)
Phone No.- 0268-2565296



E Mail:
dl_nadiad@gmail.com

જિલ્લા પંચાયતના નડિયાદ
કચેરાલુક ઇજનેરશ્રીની કચેરી.
ગુજરાત પાણી પુરવઠા અને ગટર વ્યવસ્થા બોર્ડ
પ્લો નં - 30૮,૫૫૦૬ - ડી. ડી.સી. માલ,
મરદાર પટેલ ભવન,
મીલ રોડ, નડિયાદ - ૩૮૭૦૦૧
જિલ્લો - ખેડા(ગુજરાત)
ફોન નં - ૦૨૬૮-૨૫૬૨૯૬



TC- 11926

Test Report

Name & Address of Customer *:-

Podar International School
Juna Dumral Road,
Nadiad
Tal.Nadiad
Dist.Kheda

Customer Reference No. *: NI/DL/01/01/2026

Sample Submitted by: Customer
Date of Sample Collection: 01.01.2026
Date of Sample Receipt: 01.01.2026
Analysis Starting Date: 02.01.2026
Analysis Completion Date: 02.01.2026
ULR No: TC11926260000005F

Test Report No:	2086/2025-26	Discipline :	Chemical	Group:	Water
Sample ID:	KCW-2086/01-2026	Date of Issue:			03.01.2026
Customer ID *:	5	Mode of Sample:			Satisfactory
Main Source *:	Ground Water	Source *:			Tube Well - 5
Location *:	Tap Water From R.O.Filter In The School				
Village *:	Nadiad	Habitation *:			Nadiad
Taluka *:	Nadiad	District *:			Kheda
Latitude *:	---	Longitude *:			---
Kindly find herewith the Analytical Results.			Sample Type: Drinking Water		
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value	
1	Colour	Hazen	APHA (24 th Edition), Method: 2120 B	1	
2	Odeur	-	IS 3025 (Part 5) Second Revision	Agreeable	
3	Taste	-	IS 3025 (Part 8)	Agreeable	
4	Turbidity	NTU	APHA (24 th Edition), Method: 2130 B	0.82	
5	pH at 25 °C	-	APHA (24 th Edition), Method: 4500 H ⁺ B	7.77	
6	Conductivity at 25 °C	µS/cm	APHA (24 th Edition), Method: 2510 B	109	
7	Total Dissolved Solids	mg/L	APHA (24 th Edition), Method: 2540 C	68	
8	Total Hardness (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2340 C	28	
9	Calcium (as Ca ²⁺)	mg/L	APHA (24 th Edition), Method: 3500 Ca ²⁺ B	8	
10	Magnessium (as Mg ²⁺)	mg/L	APHA (24 th Edition), Method: 3500-Mg ²⁺ B	BDL	
11	Chloride (as Cl ⁻)	mg/L	APHA (24 th Edition), Method: 4500-Cl ⁻ B	8	
12	Sulphate (as SO ₄ ²⁻)	mg/L	APHA (24 th Edition), Method: 4500-SO ₄ ²⁻ E	2.47	
13	Nitrate (as NO ₃ ⁻)	mg/L	APHA (24 th Edition), Method: 4500-NO ₃ ⁻ B	BDL	
14	Fluoride (as F ⁻)	mg/L	APHA (24 th Edition), Method: 4500-F ⁻ C	0.28	
15	Total Alkalinity (as CaCO ₃)	mg/L	APHA (24 th Edition), Method: 2320 B	48	

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits
5. Abbreviations : BDL= Below Detection Limit, UDL= Upper Detection Limit
6. Disclaimer : Information marked by " - " is provided by the customer.

Checked & Issued By:

(Signature)

Nilofar A.Luhar
Authorised Signatory

O.W.No. DL Nadiad / 30 / of 2026, Dt. 01 / 02 / 2026

End of the Test Report

(Signature)
PRINCIPAL
PODAR INTERNATIONAL SCHOOL
NADIAD
NADIAD

(Signature)
General Manager
PODAR INTERNATIONAL SCHOOL
PODAR INTERNATIONAL SCHOOL