

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHC/G/SC/24/2025

Dated: 29/1/2025

It is certified that an inspection team headed by DR. RAHUL RAUT
(Name of the officer with designation) from PRIMARY HEALTH CENTRE, GUMTHI PHED
inspected the PODAR INTERNATIONAL SCHOOL, SURVEY NO. 381, MOUZA GODHANI, NAGPUR
(Name & Address of the school) on 29/1/2025 (Date of Inspection) and on the
basis of Water Test report (Attached) bearing number RPHL [M] /311/404 dated
2/1/2025 of REGIONAL PUBLIC HEALTH LABORATORY, NAGPUR (PHED Lab)
certified that the PODAR INTERNATIONAL SCHOOL, GODHANI (Name of
school) has safe drinking water facilities for the students and members of staff of the institution.
School is also maintains the hygienic sanitation condition in the school building & the campus
as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 28/01/2026 for 01 year.

Signature with seal :

Name :

Designation :

Name & Address of the office/Department: PHC, GUMTHI

वैद्यकीय अधिकारी
प्राथमिक आरोग्य केंद्र
गुमथी

To,
PODAR INTERNATIONAL SCHOOL,
SURVEY NO. 381, MOUZA GODHANI, Nagpur
Nagpur - 441123

(Name and address of the institution)

Note : The certificate is to be issued by authorized officer/ PHED Lab/ Local bodies.

Manager
Podar International School,
Survey No.381, Mouza Godhani,
Nagpur (Rural), Dist.-Nagpur
Pin - 441123

Principal
Podar International School,
Survey No.381, Mouza Godhani
Nagpur (Rural), Dist.-Nagpur
Pin - 441203

REPORT OF CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Principal, Podar International School, Godhani, Nagpur
 Date of Collection :- 30/12/24 Date of Receipt :- 30/12/24 Date of Examination 02/01/25

(All the Analytical Results are in mg/Litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1) RO water	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	clear colorless			--	--
2.	Odour	odorless			Aggreable	Aggreable
3.	Turbidity (as N.T.U.)	0.24			1.0	5.0
4.	pH Value	7.54			6.5 to 8.5	No relaxation
5.	Fluoride as F	0.9670			1.0	1.5
6.	Nitrates (as NO ₃)	7.2030			45	No relaxation
7.	Total Dissolved solid	58.3			500	2000
8.	Iron as Fe	0.0670			0.3	No relaxation
9.	Chloride as Cl	2.0			250	1000
10.	Total Hardness as CaCO ₃	82			200	600
11.	Alkalinity as CaCO ₃	16			200	600
12.	Calcium as Ca ⁺⁺	8.016			75	200
13.	magnesium as Mg ⁺⁺	2.916			30	100
14.						
15.						
16.						
17.						
18.						
19.						
20.						

This report is restricted only for the Sample/s is Submitted to this Laboratory.

This Sample/s is / are not Collected by this Laboratory.

Manager
 Podar International School,
 Survey No.381, Mouza Godhani,
 Nagpur (Rural), Dist-Nagpur
 Pin - 441122

Principal
 Podar International School,
 Survey No.381, Mouza Godhani,
 Nagpur (Rural), Dist.-Nagpur

REMARKS

1) Sample No. (s) 17 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

2) Sample No. (s) _____ Contains _____

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

3) Sample No. (s) _____ Contains _____

Hence, this / these water source/s is /are chemically non potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. RPH/SH/311/404 /25

Date : 20/01/2025

Forwarded to Compliments To : Dr. Mini Peshmukh

Principal


Podar International School

Nagpur

With reference to letter No. _____ Dated : _____

Fees Rs. _____


Receipt No. and Date : _____


Manager

Podar International School,
Survey No.381, Mouza Godham,
Nagpur (Rural), Dist-Nagpur
Pin - 441123


Principal

Podar International School,
Survey No.381, Mouza Godham,
Nagpur (Rural), Dist.-Nagpur
Pin - 441203


Officer-in-charge
Regional Public Health Laboratory
NAGPUR-440 001