

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1135

Dated: 21/09/2024

It is certified that an inspection team headed by Dr. Kattimani R.S.

(Name of Officers with designation) from PHED

inspected the Podat International School, Shirur.

(Name & Address of the school) on 21/09/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 57/27/ dated 15/09/2024.

of Pune (PHED Lab) certified that the

Podat International School. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 20/09/2025



Signature with Seal

Name

Designation

Name & Address of the Office / Department :

To

Principal, Podat International School, Shirur
Behind Police Pump, Shirur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Maharashtra State Public Health Service

State/Regional/District Laboratory, Ahmednagar

Tel No. -

Bacterial Water Testing Report

To : Podar International School, Shirur

Inward Letter with Date : 12/09/2024

Laboratory Ref No. : 57/271

Sample Received Date : 12/09/2024

Sample Reached Date : 12/09/2024

Testing Date :-

S. No.	Details of Sample	Test Results			Remarks
		Probable Bacteria per 100 ml			
		Chloroform	thermo tolerant coliform	e coli	
1.	R.O. No. 1 First Floor	00	--	--	Potable
2.	R.O. No. 2 Ground Floor	00	--	--	
Remarks : Non-potable water can be used for drinking after appropriate chlorination and after microbial re-examination is confirmed as potable.					
Report No. 3659					
Report informed through email : 12/09/2024					
Date 20/09/2024					

- (1) District Health Officer, Zilha Parishad,
- (2) Surgeon, Dist Hospital,
- (3) Taluka Health Officer, Panchayat Samiti



REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : 12/09/2024 Date of Receipt: 12/09/2024 Date of Examination : 15/09/2024

(All the Analytical Results are in mg./Litre except pH, Turbidity)


Sr. No.	TEST PARAMETER	(1) RO-1 First Floor	(2) RO-2 Ground Floor	(3)	BIS Specification 10500 : 2012	
					Desirable Limit	Permissible Limits
1	Physical Appearance	Clear	Clear		-	-
2	Odour	Odour free	Odour free		Agreeable	Agreeable
3	Turbidity (as N.T.U)	0.11	0.12		1.0	5.0
4	pH Value	7.60	7.62		6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	52.0	58.0		250	1000
6	Nitrates (as NO ₃)	N.D.	N.D.		45	No relaxation
8	Total Hardness (as CaCO ₂)	6.0	6.0		200	600
9	Alkalinity (as CaCO ₂)	72.0	72.0		200	600
10	Total Dissolved Solids	230.0	234.0		500	2000
11	Iron (as Fe)	0.1	0.1		0.3	No relaxation
12	Fluoride (as F)	0.11	0.11		1.0	1.5
13	Other Tests (if any)					
14						
15						
16						
17						
18						
19						
20						

- This report is restricted only the Sample/s is submitted to this laboratory.
- This Samples/s is/are not collected by this Laboratory.

BEFORE ME

Adv. Vilas P. Jadhav
NOTARY
GOVERNMENT OF INDIA
SHIRUR, PUNE MAHARASHTRA

25 SEP 2024



Noted & Registered

At. Sr. No. 2208/2024

Adv. Vilas P. Jadhav
B.Com., B.B., B.M.M. in JUS
16, Shrikrishna Bungalow, Shivajinagar
Shirur, Pune - 412214
B.C. No. 993220802248



महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

राज्य/प्रादेशिक/जिल्हा आरोग्य प्रयोगशाळा, अहमदनगर दूरध्वनी क्रमांक

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, पोदार इ. स्थल शिरूर
पाठविणाऱ्यांचे पत्र क्रमांक व दिनांक :- 12/09/2024
प्रयोगशाळा संदर्भ क्रमांक :- 57/271
नमुना घेतल्याचा दिनांक :- 12/09/2024
नमुना पोहचल्याचा दिनांक :- 12/09/2024
परीक्षण सुरु केल्याचा दिनांक :-

अ. क्र.	नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रती १०० मि.ली. नमुन्यातील संभाव्य सूक्ष्मजंतूची संख्या			
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	इ. कोलाय	
१	आर. ओ. क्र. १ पहिला मजला	००	-	-	पिण्यास योग्य
२	आर. ओ. क्र. २ ताल मजला	००	-	-	

NOTARY

ADV. VILAS PIRAJI JADHAV

SHIRUR DIST. PUNE

REGD. NO. 6124

EXP. DATE 06/01/2025

GOVERNMENT OF INDIA

ATTESTED

Adv. Vilas Piraji Jadhav

NOTARY

GOVERNMENT OF INDIA

SHIRUR PUNE MAHARASHTRA

25 SEP 2024



ATTESTED
Adv. Vilas Piraji Jadhav
NOTARY
GOVERNMENT OF INDIA
SHIRUR PUNE MAHARASHTRA
25 SEP 2024

अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : 3659

दिनांक :- 20/09/2024

अभिप्राय तारेने कळविल्याचा दिनांक : 12/09/2024

प्रत सादर :

- (१) जिल्हा आरोग्य अधिकारी, जिल्हा परिषद, जिल्हा
- (२) शल्यचिकित्सक, जिल्हा रुग्णालय, जिल्हा
- (३) तालुका आरोग्य अधिकारी पंचायत समिती

अभिष्ट वैज्ञानिक अधिकारी
जिल्हा आरोग्य प्रयोग शाळा
अहमदनगर-४१४००९

State / Regional / District / Public Health Laboratory, 37545412

E-mail-ID :


Phone No. : 2251038

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection :- 12/09/2024 Date of Receipt :- 12/09/24 Date of Examination :- 15/09/2024

(All the Analytical Results are in mg./Litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1) RO-1 1st floor	(2) RO-2 Ground floor	(3)	BIS Specification 10500:2012 Normal Values	
					Desirable Limits	Permissible Limits
1	Physical Appearance	clear	clear		-	-
2	Odour	odours free	odours free		Agreeable	Agreeable
3	Turbidity (as N.T.U.)	0-11	0-12		1.0	5.0
4	pH Value	7.60	7.62		6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	52.0	58.0		250	1000
6	Nitrates (as No ₃)	N.D	N.D		45	No relaxation
7	Total Hardness (as CaCO ₃)	6.0	6.0		200	600
8	Alkalinity [as CaCO ₃]	72.0	72.0		200	600
9	Total Dissolved Solids	230.0	234.0		500	2000
10	Iron (as Fe)	0-1	0-1		0.3	No relaxation
11	Fluoride (as F)	0-11	0-11		1.0	1.5
12	Other Tests (if any)	—	—			
13						
14						
15						
16						
17						
18						
19						
20						



ATTESTED

Adv. Vilas Piraji Jadhav
NOTARY
GOVERNMENT OF INDIA
SHIRUR PUNE MAHARASHTRA

25 SEP 2024

* This report is restricted only for the Sample/s Is Submitted to this Laboratory.

* This Samples/s Is / are not Collected by this Laboratory.

(P.T.O)