



Assistant Municipal Commissioner
Hadapsar – Mundhava Office
Pune Municipal Corporation.
Out ward No:- 92६६9
Date:- १६/०३/२०२६

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Ref.No. :- Assistant Municipal Commissioner Office, Hadapsar – Mundhava Inward
No.11952 Dated.13/11/2025.

It is certificate that an inspection team headed by Mr.Nanaso Gawali Sanitary Inspector, Assistant Municipal Commissioner Office, Hadapsar – Mundhawa, Pune Municipal Corporation From Health Department (Sanitation) inspected Podar International School, S.N. 43, Ghule Vasti, Undri-Wadachi wadi Road, Taluka Haveli, Dist- Pune 411060. On 16 March 2026 and on the basis of Water test rep (attached) Bearing Number SPHL PUNE/Desk-79/1453/2025 Dated- 11/12/2025 And found Has Safe Drinking Water Facilities for the students and member of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Above Valid For a Period of One Year.

Gawali
16/03/2026

(Mr. Nanaso Gawali)

Health Inspector

Hadpsar-Mundhwa ward office

Pune Muncpal corporation

Navnath Shelar
16/03/2026

(Mr.Navnath Shelar)

Senior Health Inspector

Hadpsar-Mundhwa ward office

Pune Muncpal corporation

To,

Podar International School,

S.N. 43,Ghule Vasti, Undri- Wadachi wadi Road,

Taluka Haveli, Dist- Pune 411060.

Manoj A. Kaley

General Manager. Administration
Podar Education Trust

Principal
PRINCIPAL
PODAR INTERNATIONAL SCHOOL
UNDRI



**DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
Near St. Mary School And Church, Pune 411001**



Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com

HEALTH SERVICES

NO.:- SPHL PUNE /Desk -79 / 1453 / 2025. DATE :- 11/12/2025.



TC-11706

Report on Chemical Analysis of Water

Sent by :- Podar international school, Vadachiwadi, Undri Pune.

With Ref. letter No :-

Dated :- 28/11/2025

Date of Collection :- ----

Date of Receipt :- 28-11-2025

Date of Examination :- 02/ 12 / 2025 Onwards

(All the Analytical Results are in mg. / Lit. except pH, Turbidity.)

Parameters under Scope

SR. NO	TEST PARAMETER	S.No. - 1 (P-825) Filter Water	Test Method	BIS Specifications 10500 : 2012 Normal Values	
				Desirable limit	Permissible limit
1	pH Value	6.90	FSSAI, Manual of methods Of Analysis of Water With 2016.	6.5 to 8.5	No relaxation
2	Chlorides (as Cl)	13.90	FSSAI, Manual of methods Of Analysis of Water With 2016.	250	1000
3	Total Hardness (as Caco3)	55.55	FSSAI, Manual of methods Of Analysis of Water With 2016.	200	600
4	Alkalinity (as Caco3)	61.39	FSSAI, Manual of methods Of Analysis of Water With 2016.	200	600

Manoj A. Kaley
General Manager. Administration
Podar Education Trust

PRINCIPAL
PODAR INTERNATIONAL SCHOOL
UNDRI

Parameters not under Scope

SR. NO	TEST PARAMETER	S.No. - 1 (P-825) Filter Water	Test Method	BIS Specifications 10500 : 2012 Normal Values	
				Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---	---
2	Odour	agreeable	---	agreeable	agreeable
3	Turbidity (as N.T.U.)	0.35	FSSAI, Manual of methods Of Analysis of Water With 2016.	1.0	5.0
4	Nitrates (as No3)	2.26	A.P.H.A. 24 th Edition	45	No relaxation
5	Total Dissolved Solids	80.5	FSSAI, Manual of methods Of Analysis of Water With 2016.	500	2000
6	Iron (as Fe)	0.025	FSSAI, Manual of methods Of Analysis of Water With 2016.	1.0	No relaxation
7	Fluoride (as F)	ND	FSSAI, Manual of methods Of Analysis of Water With 2016.	1.0	1.5

- > ND :- Not detected.
- > This report is restricted only for the sample /s submitted to this laboratory.
- > It is presumed that the representative sample from the source is sent for analysis.
- > This Sample /s is /are not collected by this laboratory.

Remark :- S.No. -1 is chemically fit for drinking purpose on the basis of analysed parameters Only. However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded With Compliments To :- Podar international school, Vadachiwadi, Undri Pune.

Fees	600 /-
Receipt No.	7762142
Date	28 /11/2025

Gaikwa
Government Analyst,
State Public Health Laboratory, Pune.

Manoj A. Kaley
Manoj A. Kaley
General Manager Administration
Podar Education Trust

Principal
PRINCIPAL
PODAR INTERNATIONAL SCHOOL
UNDRI