



**ठाणे महानगरपालिका**  
**THE MUNICIPAL CORPORATION OF THE CITY OF THANE**  
**प्रदूषण नियंत्रण कक्ष**  
**POLLUTION CONTROL CELL**



E-mail : pccmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,  
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6<sup>th</sup> November 2002 vide notification No. S.O.1165(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 348  
Sample No. : P128

Date : 10 May 2023

**Water Analysis Report**

TMC/PCC/20/RO

Name Of the Organisation : M/S Podar International School

Address : Sandor Village, Surve no.252A, 255A, 256/4 and 257/3, Vasai, Tal.Vasai,  
Dist.Palghar

E\_mail ID : admin.vasai@padar.org

Date of receiving Sample : 09 May 2023

Sample Collected by : Party

Type of Water Sample : Drinking water sample ( RO Water)

Parameters	Results	Limits as per IS 10500
pH	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	20.0	250 mg/L
Total Hardness	38.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

10-May-23

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

10-May-23

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Drinking water sample ( RO Water) Water sample received to our Vakratunda Laboratory on 9/5/2023. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000043/23-24 dated 09.05.2023

This Report has been Signature Digitally.

Manager

Podar International School  
Vasai

PODAR INTERNATIONAL SCHOOL

PRINCIPAL