



**ठाणे महानगरपालिका**  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE  
**प्रदूषण नियंत्रण कक्ष**  
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,  
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6<sup>th</sup> November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 1137  
Sample No. : Q488

Date : 25 July 2024

**Water Analysis Report**

TMC/PCC/20/RO

Name Of the Organisation : M/S Podar International School

Address : Sandor Village, Surve no.252A, 255A, 256/4 and 257/3, Vasai, Tal.Vasai,  
Dist.Palghar

E\_mail ID : admin.vasai@podar.org

Date of receiving Sample : 24 July 2024

Sample Collected by : Party

Type of Water Sample : Drinking water sample ( RO Water)

Parameters	Results	Limits as per IS 10500
pH	7.80	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	110.0	250 mg/L
Total Hardness	76.0	300 mg/L
Total Coilform Bacteria ( MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

25-Jul-24

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

25-Jul-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Drinking water sample ( RO Water) Water sample received to our Vakratunda Laboratory on 24/7/2024. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000106/24-25 dated 27.07.2024

**This Report has been Signature Digitally.**