



वै.औ.अ.प. - केन्द्रीय नमक व समुद्री रसायन अनुसंधान संस्थान
(वैज्ञानिक एवं औद्योगिक अनुसंधान परिषद)

गिजुभाई बधेका मार्ग, भावनगर - 364 002 गुजरात, भारत

CSIR - CENTRAL SALT & MARINE CHEMICALS RESEARCH INSTITUTE

(Council of Scientific & Industrial Research)

Gijubhai Badheka Marg, Bhavnagar - 364 002, Gujarat, India

Ph. - 0278-2567462/0278-2567780 - Extn. 7800

Fax - +91 278 2567552

Email: bdim@csmcri.org kamlesh@csmcri.res.in Web: www.csmcni.res.in

Dr. Nikhilesh Trivedi
Scientist, BDIM

Email: nikhilesht@csmcni.res.in

पंजीकृत डाक

सं. 15/Test/2025-26/5269

दिनांक: 04/08/2025

To,
Principal
Podar International School,
Bhavnagar

महोदय,

आप के द्वारा सम्पन्न विश्लेषण के लिये धिरे गए थे उनका परिणाम इस प्रकार है

Analysis Report (Water Analysis)

Parameters	Sample - 1
TDS	52 ppm
pH	6.44
Total Hardness	28 ppm
Hardness as Calcium only	16 ppm
Hardness as Magnesium only	12 ppm
Alkalinity (Phenolphthalein)	NIL
Alkalinity (Methyl Orange)	20 ppm
Chloride	22 ppm
Sulphate	NIL


Thanking You,

Dr. Nikhilesh Trivedi


Disclaimer: Content of this analysis report is meant for information only and you will not use the content of this report for any advertisement, evidence, and litigation or quote as certificate to a third party

HQ Council of Scientific & Industrial Research, Anusandhan Bhawan, 2 Rati Marg, New Delhi-110 001 <http://www.csir.res.in>

• INNOVATIONS THAT REACH THE PEOPLE


PRINCIPAL
PODAR INTERNATIONAL SCHOOL
BHAVNAGAR

General Manager
(Saurashtra Region)
Podar International School



Dr. R. K. Sinha
Medical Officer of Health

Health Department

Opp. Galaxy Cinema, Sir Mangalsinhji Road,
Bhavnagar Municipal Corporation, Bhavnagar
Tel / Fax : 0278 - 2430249
E-mail: moh_bhavnagar@yahoo.in

BMC/H.O NO 313

Dt 09/06/2017

TO WHOM SO EVER IT MAY CONCERN
HEALTH & SANITATION CERTIFICATE

This is to certify that, we have inspected and verified all the hygiene and sanitation levels of PODAR INTERNATIONAL SCHOOL, FULSAR, BHAVNAGAR.

We further confirm that sanitary and plumbing accessories fitting on the floors such as wc, urinals, water coolers, water tanks, R.O. System are adequate on all the floors to meet the requirements of school children and staff also. Further the underground and overhead tanks are periodically cleaned.

With regards to sanitation, proper structured preventive maintenance is carried out for the entire drainage system both vertical and underground on view to prevent overflow of waste water and thereby ensuring high level of hygiene and sanitation inside the school premises.

June 9, 2017

(Signature)
DEVANG A. JOSHI
Food Safety Officer
Health Department
Bhavnagar Municipal Corporation
Bhavnagar-364001.

(Signature)

(Signature)
PRINCIPAL
PODAR INTERNATIONAL SCHOOL
BHAVNAGAR

(Signature)
General Manager
(Saurashtra Region)
Podar International School