

Annexure D

BUILDING SAFETY CERTIFICATE

No.

Dated: 31/12/2024

It is certified that the existing building Podar International School at Plot No. 75 / Survey No. 307/1+308/1+309/501/1+501/2/1 / Khasra No. (s) Chavadigram, Opp.kadi Kadi Karkhana, Taluka Chalisgaon / Disctriect Jalgaon is having block(s)/Floors as per details below:-

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	0 Basement, 1 Ground Floor 2 Upper Floors	NA	NA	NA	NA	NA

The building is occupied by **Podar International School, Plot No. 75 / Survey No. 307/1+308/1+309/501/1+501/2/1 / Khasra No. (s) Chhayadigram, Opp. Kadi Karkhana, Tal.Chalisgaon** have complied with the Building safety requirements in accordance with National Building code Rules and verified by the officers concerned of **P.W.Sub-Division**, on 23/12/2024 in the presence of **Anil N. Baisane**, Sub-Divisional Engineer, P.W.Sub Division, Chalisgaon 424101 and the building/ premises is fit for occupancy for running the school from **31/12/2024** for a period of 1 year in accordance with rule and subject to compliance of the specific conditions as appended.

1. Drive way of minimum 6.00 m shall be provided without any Obstruction around main building for fire extinguisher vehicle.
2. Water proofing for First Floor Toilet Blocks should be done properly.

Issued on **31/12/2024** at P.W.Sub Division, Chalisgaon by Sub-Divisional Engineer.

*Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

जा.क्र.सा.बां.उविचा/1266 /सन 2025
उपविभागीय अभियंता यांचे कार्यालय
सार्वजनिक बांधकाम उपविभाग, चाळीसागंज
दिनांक : 31 / 12 / 2025


Anil N. Baisane
Sub-Divisional Engineer
P.W. Sub-Division, Chalisgaon.