



FORM B 13.3

## FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2024/00060057  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2024/00060057/R1

Date: 07/06/2024

Building Occupancy/Category: Educational (non-residential)

To,

SACHIN RAMESH BHARDIYA  
- GANDHIDHAM MUNDRA ROAD SHINAY GANDHIDHAM GANDHIDHAM Kachchh 370201  
Fire Region: Rajkot RFO  
Mobile No: 8291992538 Email ID: admin.gandhidham@podar.org

This has reference to your Application No. 2024/00060085 dated 31/05/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise PODAR INTERNATIONAL SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: S.R. NO. 303/1
4. Village Name: GANDHIDHAM
5. Name of Block(s): PODAR INTERNATIONAL SCHOOL

The building/premise was inspected on 07/06/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 07/06/2024
2. Six monthly inspection was done on 07/06/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 07/06/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



### Digitally Verified

Digitally verified by: Kamlesh Matiya  
Fire Safety Officer - General (FSO-G)  
2021/000021

Date: 07/06/2024  
Time: 09:05 AM



FSCA/O/RFORAJ/2024/00060057/R1

PRINCIPAL

Podar International School

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycap.in](http://www.gujfiresafetycap.in).

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.