



TEST REPORT

Report No. : 026678/2025	Date of report : 27.12.2025
Sample code No. : 776543	Page(s) : 1 of 1
Sample collected on : 22.12.2025	Source : RO WATER
Name of customer : M/s Podar International School, Raipur	
Address : NH-30, Canal Road, Mana Basti, Raipur (C.G)	

Sl. No.	PARAMETER TESTED	UNITS	RESULT	IS: 10500-2012 Drinking water specification (Second Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate source
PHYSICO-CHEMICAL					
1.	Odour		Agreeable	Agreeable	Agreeable
2.	Taste		Agreeable	Agreeable	Agreeable
3.	Turbidity	NTU	1.0	1	5
4.	pH value		6.5	6.5-8.5	No relaxation
5.	Total Dissolved Solids	mg/l	22.0	500	2000
6.	Total Hardness as CaCO ₃	mg/l	14.1	200	600
7.	Calcium as Ca ⁺⁺	mg/l	7.1	75	200
8.	Magnesium as Mg ⁺⁺	mg/l	1.0	30	100
9.	Total Alkalinity as CaCO ₃	mg/l	16.0	200	600
10.	Chloride as Cl ⁻	mg/l	7.6	250	1000
11.	Total Iron as Fe	mg/l	<0.01	0.3	No relaxation
12.	Sulphate as SO ₄ ⁻²	mg/l	2.1	200	400
13.	Fluoride as F ⁻	mg/l	<0.01	1.0	1.5
14.	Nitrate as NO ₃ ⁻	mg/l	<0.01	45	No relaxation
BACTERIOLOGICAL				Requirement (Acceptable Limit)	
15.	Total Coliform (MPN/100ml)		Zero	Shall not be detectable in any 100 ml sample	
16.	Faecal Coliform (MPN/100ml)		Zero	Shall not be detectable in any 100 ml sample	
17.	E. coli in 100 ml of sample		Absent	Shall not be detectable in any 100 ml sample	

Remarks: The above water sample conforms to IS: 10500-2012(Second Revision), Drinking Water Specification with respect to the tests conducted.

Lab Address : Bharati Tower, Block - A, Ground floor
Forest Park, Bhubaneswar -9
Mob-9861130540,7540902688
*Podar International School
Raipur-492015 (C.G.)*

[Signature]
Manager
Podar International School
Raipur
[Signature] *[Signature]*
Authorised Signatory

Corporate Office:
B1/B2, 701, Marathon Innova
Off Ganpatrao Kadam Marg,
Lower Parel, Mumbai - 400013 India

Phone : +91-22-30449700
Fax : +91-22-30449701

Mailing Address :
P.O. Box 936
G.P.O., Mumbai-400001
India

Regd. Office :
7, Chakraberia Road (South)
Kolkata-700025, India
Phone : +91-33-24755402

Website : <http://www.eurekafishes.com>

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

Ref No 448776

Date 15.04.2025

It is certified that an inspection team headed by DR. SHRI SANJEEV KUMAR VOHRA, MEDICAL OFFICER AND SHRI SHAILESH THAKUR, RMA (Name of Officers with designation) from CHIEF MEDICAL AND HEALTH OFFICER RAIPUR (C.G.) (Name of Department/Office) inspected the PODAR INTERNATIONAL SCHOOL DISTT- RAIPUR (C.G.) (Name & Address of the School) on 08.04.2025 and found that PODAR INTERNATIONAL SCHOOL NH30, CANAL ROAD, MANA BASTI RAIPUR (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid Certificate is for a period of ONE YEAR FROM DATE OF ISSUE.

Signature with Seal : 
C.M.&H.O.
DISTT, RAIPUR, C.G.

Name . DR. SMT M BAGHEL

Designation :- C.M&H.O. RAIPUR (C.G.)

TO,

PRINCIPAL
PODAR INTERNATIONAL SCHOOL
RAIPUR (C.G.)


PRINCIPAL
Podar International School
Raipur-492015 (C.G.)


Manager
Podar International School
Raipur